

Certificate

BOOKING NO. : 19176
CERTIFICATE NO. : 19176/2018-2019

R/3, MANOHAMAGANJ, INDORE 452001 MADHYA PRADESH
Phone : +91 731 4243888 (30 LINES)
Fax : +91 731 2480583
Email : indore@choksilab.com
Website : www.choksilab.com

1. NAME OF MANUFACTURER/PARTY : DELHI WORLD PUBLIC SCHOOL

BETMA MADHYA PRADESH

1. MFG. LIC. NO.	: NM	5. REFERENCE NO. 1	: NM
2. REFERENCE NO. OF LETTER	: TE/03/18-19/001	6. REFERENCE NO. 2	: NM
3. DATE	: 20/03/2019	7. REFERENCE NO. 3	: NM
4. DATE OF RECEIPT	: 20/03/2019	8. NAME OF SAMPLE	: R.O. WATER

9. DETAILS OF RAW MATERIAL / FINAL PRODUCTS (in Bulk/Finished Pack)

(A) BATCH NO.	: NM	(G) SAMPLE QUANTITY	: 5.0 LITER
(B) BATCH SIZE	: NM	(H) SEALED	: UNSEALED
(C) A.R. NO.	: NM	(I) PACKING	: PLASTIC JAR
(D) DATE OF MFG.	: N/A	(J) STARTING DATE	: 22/03/2019
(E) DATE OF EXPIRY	: NM	(K) ENDING DATE	: 01/04/2019
(F) MFG NAME	: NM	(L) PAGE NO.	: Page 1 of 2

AS PER IS-10500 - 2012 (Amendment-2)

SR	TEST NAME	UNIT	RESULT	SPECIFICATIONS	METHOD OF TEST
	Description	N/A	Clear colour liquid free from suspended particulates		
1	Colour	Hazen Unit	Less than 1	Max. 5	IS-3025 (PART-4) -1984
2	Odour	N/A	Agreeable	Agreeable	IS-3025 (PART-5) -1984
3	Taste	N/A	Agreeable	Agreeable	IS-3025 (PART-8) -1984
4	Turbidity	NTU	0.2	Max. 1	IS-3025 (PART-10) -1984
5	Total dissolved solids	mg/L	88	Max. 500	IS-3025 (PART-16) -1984
6	pH value	N/A	7.0	6.5 to 8.5	IS-3025 (PART-11) -1983
7	Total Hardness, as CaCO ₃	mg/L	81.6	Max. 200	IS-3025 (PART-21) -2009
8	Calcium as Ca	mg/L	22.9	Max. 75	IS-3025 (PART-40) -1991
9	Chloride, as Cl	mg/L	12.3	Max. 250	IS-3025 (PART-32) -1988
10	Sulphate, as SO ₄	mg/L	5.9 (MDL=1.0)	Max. 200	IS-3025 (PART-24) -1986
11	Nitrate as NO ₃	mg/L	7.1 (MDL=0.1)	Max. 45	IS-3025 (PART-34) -1988

For Choksi Laboratories Ltd.
Authorized Signatory

Remarks :

- Certificate Issue Date: 05/04/2019.
- N/A refer to "Not Applicable"
- Sample not drawn by CLL representative, and sample information as furnished by client
- Test report shall not be reproduced either in part or in full, without written approval of CLL Management.
- CLL does not give any opinion or interpretation of the same
- MDL refer to "Method Detection Limit"

CONTD. ON NEXT PAGE.

Kavish Vyas (MCA 2012)

General Manager
Agro & Agricultural
QMS/51-2015/01
AUTHORISED SIGNATORY

Note : **Alisha Education Society**
Please see overleaf for terms & conditions
Director

Principal
DELHI WORLD PUBLIC SCHOOL